

Little Hope-Moore Water Supply Corporation

150 FM 16

(903) 253-5565

Canton, Texas 75103

Backflow Prevention Devices

Operational Procedure

Compliance with Texas Water Code 290.44(H)

Any Member of the Little Hope-Moore Water Supply Corporation whose service could cause a potential hazard to the water system will be required to have installed a “testable backflow prevention device” at their expense. These devices are required to be tested upon installation and annually thereafter. All tests, both initial and annual, will also be at the member’s expense and be reported to the Corporation’s office in writing.

Approved at the meeting of the Board of Directors of Little Hope-Moore Water Supply Corporation.

Date:

Board of Directors President